



# SGS

CERT No. SGS-R13-0380

## CERTIFICATE OF COMPLIANCE


Certificate Holder : BMT Co., Ltd.  
Product Submitted : MCPD PANEL  
Model : MDP-400

The equipment has been tested in accordance with GR-63-CORE 5.4.1 Earthquake Test (Issue 3, March 2006) Zone3 level at March 21 and this equipment maintains required functional condition without any physical damages and hence hereby certify that this equipment complies with above mentioned standard.

Test Date March 21, 2013

Issued Date March 28, 2013

SGS Korea Co., Ltd.



Copyright of this certificate is owned by SGS Korea Co., Ltd. and may not be reproduced except in full, without prior written permission of General Manager of the SGS Korea Co., Ltd.

SGS Korea Co., Ltd.

398-1, Gomae-dong, Giheung-gu, Yongin-si, Gyeonggi-do, 446-901, Korea.

t +82 (0)31 240 6601 f +82 (0)31 240 6629 www.kr.sgs.com/ee

Member of SGS Group (Société Générale de Surveillance)

This document is issued by the Company under its General Conditions of Service printed overleaf. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGSPAPER  
10689082

